Test Report SL52025258555101TX Date:May 27,2020 Page 1 of 4

The following sample(s) was/were submitted and identified on behalf of the client as:

Sample Description : (A)Protective apparel (Isolation gown) (Claimed Level 3)

Composition : CPE Sample Color : (A)blue

Sample Receiving Date : May 25, 2020

Testing Period : May 25, 2020 - May 27, 2020

Test Result(s) : Unless otherwise stated the results shown in this test report refer only to the

sample(s) tested, for further details, please refer to the following page(s).

Test Performed : Selected test(s) as requested by applicant

Conclusion: the provided sample meet ANSI/AAMI PB70-2012 Level 3 requirement which is claimed by client

Sara Guo (Account Executive)

Sara Gan

Test Report

SL52025258555101TX

Date: May 27,2020

Page 2 of 4

Test Result

<u>Liquid Barrier Performance and Classification of Protective apparel and Drapes Intended for Use in Health Care Facilities</u>

(ANSI/AAMI PB70-2012)

Section 4.2.1 Water Resistance: Hydrostatic Pressure Test

(AATCC 127-2018; Hydrostatic Head; Rate of increase of water pressure:60mbar/min; temp. of distilled water: 21℃, fabric face side of water)

As received

Water Column (cmH ₂ O)	1#	2#	3#	4#	5#
Area A (Critical zone-front)	>50.0	>50.0	>50.0	>50.0	>50.0
Area B (Critical zone-sleeve)	>50.0	>50.0	>50.0	>50.0	>50.0
Area C (Critical zone-Back)	>50.0	>50.0	>50.0	>50.0	>50.0
Seam between areas A&B	>50.0	>50.0	>50.0	>50.0	>50.0
Seam between areas A&C	>50.0	>50.0	>50.0	>50.0	>50.0
Seam between areas B&C	>50.0	>50.0	>50.0	>50.0	>50.0

Remark:

- Level 2: all critical zone components shall have a hydrostatic resistance of at least 20cmH₂O
- Level 3: all critical zone components shall have a hydrostatic resistance of at least 50cmH₂O

Section 4.2.1 Water Resistance: Impact Penetration Test

(AATCC 42-2017)

As received

Weight of blotter gained (g)	1#	2#	3#	4#	5#
Area A (Critical zone-front)	0.0	0.0	0.0	0.0	0.0
Area B (Critical zone-sleeve)	0.0	0.0	0.0	0.0	0.0
Area C (Critical zone-Back)	0.0	0.0	0.0	0.0	0.0
Seam between areas A&B	0.0	0.0	0.0	0.0	0.0
Seam between areas A&C	0.0	0.0	0.0	0.0	0.0
Seam between areas B&C	0.0	0.0	0.0	0.0	0.0

Remark:

- Level 1: all critical zone components shall have a blotter weight gain of no more than 4.5grams(g)
- Level 2: all critical zone components shall have a blotter weight gain of no more than 1.0 grams(g)
- Level 3: all critical zone components shall have a blotter weight gain of no more than 1.0 grams(g)

Test Report

SL52025258555101TX

Date: May 27,2020

Page 3 of 4

Barrier performance of each component and final classification commended

	Impact Penetration Test AATCC 42 (g)	Hydrostatic Pressure Test AATCC 127 (cmH ₂ O)	Resistance to Bacteriophage Phi-X174 ASTM F 1671	Level	Final classification	
Area A (Critical zone- front)	0.0	>50.0	1	Level 3	Level 3	
Area B (Critical zone- sleeve)	0.0	>50.0	1	Level 3		
Area C (Critical zone- Back)	0.0	>50.0	1	Level 3		
Seam between areas A&B	0.0	>50.0	1	Level 3		
Seam between areas A&C	0.0	>50.0	1	Level 3		
Seam between areas B&C	0.0	>50.0	1	Level 3		

Remark:


- The barrier performance of all critical zone components, including seams and points of attachments, shall be determined. The classification of isolation gown shall be a number denoting the performance of the critical zone component having the lower barrier performance.
- Level 1: Impact Penetration Test-AATCC 42: ≤4.5g;
- Level 2: Impact Penetration Test-AATCC 42: ≤1.0g; Hydrostatic Pressure Test-AATCC 127:
 ≥20cmH₂O;
- Level 3: Impact Penetration Test-AATCC 42: ≤1.0g; Hydrostatic Pressure Test-AATCC 127:
 ≥50cmH₂O;
- Level 4: Resistance to Bacteriophage Phi-X174-ASTM F 1671: Pass.
- Only test the barrier performance of the sample. Label request, construction and other classed in ANSI/AAMI PB70-2012 is not checked.

Test Report

SL52025258555101TX

Date:May 27,2020

Page 4 of 4



The statement of conformity in this test report is only based on measured values by the laboratory and does not take their uncertainties into consideration.

End of Report